

MAY, 2010

CRESLINE-TYPE PSM PVC SDR 35 SEWER PIPE MEETS ALL THE DIMENSIONAL, CHEMICAL, AND PHYSICAL REQUIREMENTS, AS OUTLINED IN ASTM D-3034 AND SHALL BE MADE OF PVC PLASTIC HAVING A CELL CLASSIFICATION OF 12364, AS DEFINED IN ASTM D-1784.

PIPE DIMENSIONS

<u>SIZE</u>	<u>O.D.</u>	<u>MIN WALL</u>
3"	3.250	.093
4"	4.215	.120
6"	6.275	.180
8"	8.400	.240

CRESLINE GASKET JOINT SDR 35 SEWER PIPE COMES WITH AN INSERTION DEPTH RING MARKED ON THE BEVELED SPIGOT END OF THE PIPE. GASKETS ARE REINFORCED RUBBER RINGS AND PERMANENTLY INSTALLED IN AN INTEGRAL BELL. LUBRICANT SHALL BE FURNISHED AND SHOULD BE USED IN THE JOINING PROCESS.

PHYSICAL PROPERTIES

<u>PROPERTIES</u>	<u>UNITS</u>	<u>TEST METHOD</u>	<u>PVC 12364</u>
SPECIFIC GRAVITY		ASTM D-792	1.40
TENSILE STRENGTH	PSI	ASTM D-638	6,000
MODULUS OF ELASTICITY	PSI	ASTM D-638	440,000
IZOD IMPACT STRENGTH	FT. LBS./IN.	ASTM D-256	.65

CRESLINE - WEST, INC.

CORPORATE HEADQUARTERS: 600 CROSS POINTE BOULEVARD · EVANSVILLE, IN 47715 · TELEPHONE (812) 428-9300

PLANT: 3747 W. BUCKEYE ROAD · PHOENIX, AZ 85009 · TELEPHONE (602) 269-5161

WAREHOUSE: 1930 W. WHITESBRIDGE ROAD · FRESNO, CA 93706 · TELEPHONE (559) 486-1840

www.cresline.com